


TRENCH SECTION

NOTES:

- 1) REFER TO SECTION 02223 OF THE SPECIFICATIONS FOR TRENCHING, BACKFILLING AND COMPACTING OF PIPELINE TRENCHES
- 2) CONCRETE CRADLE SHALL BE USED AS DIRECTED BY THE DISTRICT ENGINEER WHEN THE TRENCH WIDTH AT THE UPPER LIMIT OF THE PIPE ZONE EXCEEDS THE MAX WIDTH SPECIFIED ON SP-02
- 3) ALTERNATE PIPE MATERIALS MAY BE USED, SUCH AS AWWA C-900 OR C-905 WATERPIPE AS DIRECTED BY THE DISTRICT ENGINEER
- 4) FOR PIPE BEDDING AND TRENCH BACKFILL SEE SP-02



LEGEND ON PLANS

CONCRETE PIPE CRADLE

WATER AGENCIES STANDARDS

COMMITTEE APPROVAL: 03/01/2001

DRAWING NUMBER: SP-03

K:\WAS\Sewer\Approved 3-1-01\sp03.dgn 21-SEP-2001 16:02