



NOTES:

- 1) REFER TO SECTION 15108 OF THE SPECIFICATIONS
- 2) PROTECTION POSTS SHALL BE INSTALLED AS CALLED FOR ON THE PLANS OR AS DIRECTED BY THE ENGINEER PER WM-04
- 3) AN EASEMENT MAY BE NEEDED DEPENDING ON LOCATION OF ENCLOSURE
- 4) THE ENCLOSURE SHALL BE CHOCOLATE BROWN AS MANUFACTURED IN ACCORDANCE WITH THE APPROVED MATERIALS LIST
- 5) 1200mm (24") MINIMUM CLEARANCE SHALL BE MAINTAINED ALL AROUND PAD WHEN INSTALLED WITH OR BY A WALL OR OTHER OBSTRUCTIONS
- 6) IF THE CONCRETE SLAB IS TO BE INSTALLED ADJACENT TO A CONCRETE SIDEWALK A COLD JOINT STRIP SHALL BE INSTALLED
- 7) AIR & VACUUM VALVES & APPURTENANCES INSTALLED FOR THE USE OF RECYCLED WATER SHALL BE IDENTIFIED AS DESCRIBED IN SECTION 15151 OF THE SPECIFICATIONS
- 8) MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST



LEGEND ON PLANS

100mm & 150mm (4" & 6") AIR & VACUUM VALVE ENCLOSURE LOCATIONS

WATER AGENCIES' STANDARDS

COMMITTEE APPROVAL: 09/28/2009

DRAWING NUMBER: WA-06