


NOTES:

- 1) REFER TO SECTION 15074 OF THE SPECIFICATIONS
- 2) SET TOP OF METER BOX FLUSH WITH SIDEWALK, CURB OR FINISH GRADE
- 3) LOCATE METER BOX AS SHOWN ON WS-03
- 4) INSTALL WARNING/IDENTIFICATION TAPE AS SHOWN ON WP-01
- 5) FOR BLOWOFF INSTALLATION AT END OF MAIN SEE WB-04
- 6) BLOWOFF ASSEMBLIES INSTALLED FOR THE USE OF RECYCLED WATER SHALL BE IDENTIFIED AS DESCRIBED IN SECTION 15151 OF THE SPECIFICATIONS
- 7) CONNECTIONS TO STEEL MAINS SHALL BE IN ACCORDANCE WITH SECTION 15061 AND AS SHOWN ON WB-04
- 8) 45° BEND SHALL BE USED FOR MAINS UP TO 750mm (30"). 90° BEND SHALL BE USED FOR MAINS IN EXCESS OF 750mm (30") AS DIRECTED BY THE ENGINEER
- 9) CAM & GROOVE FITTING ADAPTER SHALL BE DRILLED AND TAPPED AS REQUIRED FOR THE PRESSURE RELEASE PET COCK
- 10) MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST



LEGEND ON PLANS

ITEM NO	SIZE AND DESCRIPTION	ITEM NO	SIZE AND DESCRIPTION
1	POLYMER METER BOX WITH LID 430mm x 760mm (17" x 30") SEE NOTE 3	8	CONCRETE THRUST BLOCK SEE WT-01
2	150mm (6") CAM & GROOVE FITTING ADAPTER x MIPT WITH LOCKING DUST CAP, SEE NOTE 9	9	150mm (6") FLG x MJ/PO 90° BEND
3	6mm (1/4") PRESSURE RELEASE PET COCK	10	150mm (6") C-900 PVC PIPE
4	TRACER WIRE (AS REQUIRED), SEE WP-01	11	200mm (8") GATE WELL WITH LID SEE WV-01 OR WV-02
5	150mm (6") FLANGED COMPANION x FIPT	12	150mm (6") FLG x MJ/PO/FLG RWGV
6	10mm (3/8") ROCK 100mm TO 150mm (4" TO 6") DEEP	13	150mm (6") FLG x MJ/PO ADAPTER (IF REQUIRED)
7	150mm (6") FLG DI PIPE x REQUIRED LENGTH (MAXIMUM OF 2 SPOOLS)	14	WATER MAIN
		15	SIZE x 150mm (6"), MJ/PO/FLG x FLG TEE
		16	150mm (6") FLG'D 45° BEND, SEE NOTE 8
		17	150mm (6") x 600mm (24") FLG DI SPOOL

150mm (6 inch) BLOWOFF INSTALLATION

WATER AGENCIES STANDARDS

COMMITTEE APPROVAL: 11/03/2006

DRAWING NUMBER: **WB-03**

h:\WAS&WASDC\WAS&WASDC11-03-06\wb03.dgn
PEN: JBL: k:\table\WASDETAIL.PEN
28-NOV-2006 20:00 keing