


NOTES:

- 1) REFER TO SECTIONS 15000 AND 15074 OF THE SPECIFICATIONS
- 2) SET TOP OF METER BOX 50mm (2") ABOVE FINISH GRADE
- 3) BLOWOFF ASSEMBLIES INSTALLED FOR THE USE OF RECYCLED WATER SHALL BE IDENTIFIED AS DESCRIBED IN SECTION 15151 OF THE SPECIFICATIONS
- 4) THE INSTALLATION OF TEMPORARY END CAPS AND BLOWOFFS FOR THE USE OF TESTING AND FLUSHING OF NEW MAINS OR TEMPORARY MAINTENANCE OR SERVICE OF EXISTING WATER MAINS ONLY
- 5) CAM & GROOVE FITTING ADAPTER SHALL BE DRILLED AND TAPPED AS REQUIRED FOR THE PRESSURE RELEASE PET COCK
- 6) MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST



LEGEND ON PLANS

ITEM NO	SIZE AND DESCRIPTION	ITEM NO	SIZE AND DESCRIPTION
1	POLYMER METER BOX WITH LID 430mm x 760mm (17" x 30")	7	50mm (2") CLOSE NIPPLE IPT
2	50mm (2") CAM & GROOVE FITTING ADAPTER x MIPT WITH LOCKING DUST CAP. SEE NOTE 5	8	50mm (2") COMPRESSION x FIPT BALL VALVE WITH HANDLE
3	6mm (1/4") PRESSURE RELEASE PET COCK	9	10mm (3/8") ROCK 150mm (6") DEEP
4	50mm (2") x REQUIRED LENGTH COPPER PIPE TYPE "K" RIGID OR SOFT	10	DI END CAP WITH 63mm (2 1/2") FIPT OUTLET
5	CONCRETE THRUST BLOCK SEE WT-01	11	WATER MAIN
6	50mm (2") 90° BRONZE COMP x FIPT ELL	12	63mm (2 1/2") x 50mm (2") NYLON DIELECTRIC BUSHING

**TEMPORARY END CAP AND
50mm (2") BLOWOFF INSTALLATION**

WATER AGENCIES STANDARDS

COMMITTEE APPROVAL: 12/31/2004

DRAWING NUMBER: WB-05