


NOTES:

- 1) REFER TO SECTION 15074 OF THE SPECIFICATIONS
 - 2) INSTALL WARNING/IDENTIFICATION TAPE AS SHOWN ON WP-01
 - 3) FOR INSTALLATION AT END OF MAIN REFER TO WB-04
 - 4) BLOWOFF ASSEMBLIES INSTALLED FOR THE USE OF RECYCLED WATER SHALL BE IDENTIFIED AS DESCRIBED IN SECTION 15151 OF THE SPECIFICATIONS
 - 5) CONNECTIONS TO STEEL MAINS SHALL BE IN ACCORDANCE WITH SECTION 15061
 - 6) CAM & GROOVE FITTING ADAPTER SHALL BE DRILLED AND TAPPED AS REQUIRED FOR THE PRESSURE RELEASE PET COCK
 - 7) LIDS SHALL BE MANUFACTURED WITH THE WORD "WATER" OR "RECYCLED WATER" AS SHOWN ON WV-03
 - 8) MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST
- LEGEND ON PLANS



ITEM NO	SIZE AND DESCRIPTION	ITEM NO	SIZE AND DESCRIPTION
1	200mm (8") HIGH x 200mm (8") WIDE CONCRETE RING	8	300mm (12") SDR 35 PVC PIPE x 600mm (24") LONG GATE WELL
2	300mm (12") 2-PIECE FRAME AND LID VALVE BOX, SEE NOTE 7	9	200mm (8") HIGH x 200mm (8") WIDE ASPHALT CONCRETE RING
3	50mm (2") CAM & GROOVE FITTING ADAPTER x MIPT WITH LOCKING DUST CAP SEE NOTE 8	10	TRACER WIRE (AS REQUIRED), SEE WP-01
4	6mm (1/4") PRESSURE RELEASE PET COCK	11	50mm (2") BRONZE COMP x FLG ANGLE METER STOP WITH LOCK WING
5	50mm (2") 90° BRONZE MIPT x FIPT ELL	12	50mm (2") x REQUIRED LENGTH COPPER PIPE TYPE "K" RIGID OR SOFT
6	50mm (2") OVAL METER FLANGE FLG x FIPT, WITH GASKET	13	50mm (2") 90° BRONZE COMPRESSION ELL
7	10mm (3/8") ROCK 100mm TO 150mm (4" TO 6") DEEP	14	50mm (2") BRONZE MIPT x COMPRESSION CORPORATION STOP
		15	SIZE x 50mm (2") SERVICE SADDLE
		16	WATER MAIN

50mm (2") BLOWOFF INSTALLATION
IN 300mm (12") CAN

WATER AGENCIES' STANDARDS

COMMITTEE APPROVAL: 11/23/2011

DRAWING NUMBER: WB-06