

CONSTRUCTION REQUIREMENTS FOR WATER, RECYCLED WATER AND SEWER MAINS

CASE 1: NEW RECYCLED WATER OR SEWER MAINS

ZONE

- A SPECIAL PERMISSION REQUIRED. DO NOT LOCATE ANY PARALLEL SEWER OR RECYCLED WATER MAINS IN THIS AREA WITHOUT DISTRICT AND STATE HEALTH DEPARTMENT APPROVAL
- B PVC SEWER PIPE WITH PUSH-ON TYPE RUBBER RING JOINTS FOR SEWER MAINS
C-900,CL305 OR C-905,CL235 PVC PIPE WITH PUSH ON TYPE RUBBER RING JOINTS FOR RECYCLED WATER MAINS
- C A 6.1m (20') SECTION OF PVC SEWER PIPE CENTERED AT THE MAIN BEING CROSSED, OR SEWER PIPE INSTALLED IN A CASING (FOR SEWER MAINS)
A 6.1m (20') SECTION OF C-900,CL305 OR C-905,CL235 PVC PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- D A 6.1m (20') SECTION OF PVC SEWER PIPE CENTERED AT THE MAIN BEING CROSSED, OR SEWER PIPE INSTALLED IN A CASING (FOR SEWER MAINS)
A 6.1m (20') SECTION OF C-900,CL305 OR C-905,CL235 PVC PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- P PROHIBITED ZONE; NO SEWER, WATER OR RECYCLED WATER MAINS; SECTION 64630 (e) (2) CALIFORNIA ADMINISTRATIVE CODE, TITLE 22

CONSTRUCTION REQUIREMENTS FOR WATER, RECYCLED WATER AND SEWER MAINS

CASE 2: NEW WATER OR RECYCLED WATER MAINS

ZONE

- A SPECIAL PERMISSION REQUIRED. DO NOT LOCATE ANY PARALLEL WATER OR RECYCLED WATER MAINS IN THIS AREA WITHOUT DISTRICT AND STATE HEALTH DEPARTMENT APPROVAL
- B C-900,CL305 OR C-905,CL235 PVC PIPE WITH PUSH ON TYPE RUBBER RING JOINTS FOR WATER MAINS
C-900,CL305 OR C-905,CL235 PVC PIPE WITH PUSH ON TYPE RUBBER RING JOINTS FOR RECYCLED WATER MAINS
- C A 6.1m (20') SECTION OF C-900,CL305 OR C-905,CL235 PVC PIPE CENTERED AT THE MAIN BEING CROSSED, OR WATER PIPE INSTALLED IN A CASING (FOR WATER MAINS)
A 6.1m (20') SECTION OF C-900,CL305 OR C-905,CL235 PVC PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- D A 6.1m (20') SECTION OF C-900,CL305 OR C-905,CL235 PVC PIPE CENTERED AT THE MAIN BEING CROSSED, OR WATER PIPE INSTALLED IN A CASING (FOR WATER MAINS)
A 6.1m (20') SECTION OF C-900,CL305 OR C-905,CL235 PVC, PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- P PROHIBITED ZONE; NO SEWER, WATER OR RECYCLED WATER MAINS; SECTION 64630 (e) (2) CALIFORNIA ADMINISTRATIVE CODE, TITLE 22

REFER TO THE WATER AGENCIES' STANDARDS DESIGN GUIDE FOR PIPE SEPARATION REQUIREMENTS

WATER, RECYCLED WATER AND SEWER MAIN
PARALLEL AND PERPENDICULAR
SEPARATION NOTES

WATER AGENCIES' STANDARDS

COMMITTEE APPROVAL: 11/23/2011

DRAWING NUMBER: WI-03