



RECYCLED
WATER



POTABLE
WATER

GATE WELL LIDS

SEE NOTE 2 BELOW

COLOR	GATE WELL LIDS USED FOR:
RED	NORMALLY CLOSED SYSTEM VALVES (NCV)
PURPLE	RECYCLED WATER VALVES: LINE VALVES & AIR VALVES
YELLOW	POTABLE WATER VALVES: LINE VALVES, FIRE SERVICES, & AIR VALVES
WHITE	FIRE HYDRANTS

GATE WELL LID COLORS

SEE NOTE 5 BELOW

COLOR	GATE WELL AND LIDS USED FOR:
RED	NORMALLY CLOSED SYSTEM VALVES (NCV)
WHITE	RESILIENT WEDGE GATE VALVES
GREEN	BUTTERFLY VALVES

PAINTED IDENTIFICATION MARKING

SEE NOTE 4 BELOW

NOTES:

- 1) REFER TO SECTION 15000 OF THE SPECIFICATIONS
- 2) GATE WELL LIDS SHALL BE CAST WITH THE "AGENCY NAME" AND THE WORD "WATER" FOR USE WITH POTABLE WATER SYSTEMS AND "RECYCLED" FOR USE WITH RECYCLED WATER SYSTEMS. LIDS SHALL INCLUDE A LIFTING SLOT
- 3) PVC GATE WELLS SHALL BE MANUFACTURED IN WHITE OR BLUE FOR USE WITH POTABLE WATER, AND PURPLE FOR USE WITH RECYCLED WATER
- 4) THE INSIDE PORTIONS OF THE GATE WELL LID AND PVC GATE WELL SHALL BE IDENTIFIED WITH A PAINTED IDENTIFICATION MARKING. IDENTIFICATION MARKINGS SHALL BE OF THE COLORS SHOWN ABOVE
- 5) THE TOP EXTERIOR PORTION OF GATE WELL LIDS SHALL BE PAINTED WITH COLORS TO IDENTIFY THE USE OF THE VALVE INSTALLED, AS SHOWN ABOVE
- 6) INSTALLATION FOR THE USE OF RECYCLED WATER SHALL BE IDENTIFIED AS DESCRIBED IN SECTION 15151 OF THE SPECS AND AS NOTED ABOVE
- 7) MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST

GATE WELL IDENTIFICATION

WATER AGENCIES STANDARDS

COMMITTEE APPROVAL: 11/16/2007

DRAWING NUMBER: **WV-03**

h:\WAS&WASDC\2007\WAS&WASDC\11-16-07\WAS\StandardDrawings\Water\wv03_11-16-07.dgn
PEN TBU: k:\table\wasde\tail.pen
16-NOV-2007 11:45 keng