



DETAIL "A"

DETAIL "B"

NOTES:

- 1) REFER TO SECTION 15000 OF THE SPECIFICATIONS AND STANDARD DRAWINGS WV-01 AND WV-02
- 2) STEEL EXTENSION STEMS SHALL BE USED ONLY WHERE THE MAXIMUM LENGTH OF THE EXTENSION EXCEEDS 2.4m (8') AND AT THE REQUEST OF THE DISTRICT ENGINEER
- 3) EXTENSION STEMS SHALL BE ROUND OR SQUARE STEEL TUBING OF SOLID DESIGN (NO PINNED COUPLINGS PERMITTED)
- 4) FIBERGLASS EXTENSION STEMS MAY BE USED IN ACCORDANCE WITH THE APPROVED MATERIALS LIST
- 5) VALVES DEEPER THAN 1.5m (5') REQUIRE A VALVE STEM EXTENSION
- 6) EXTENSION STEMS SHALL NOT BE ATTACHED/BOLTED TO OPERATING NUT OF THE VALVE
- 7) MATERIALS SHALL BE SELECTED FROM THE APPROVED MATERIALS LIST

STEEL VALVE STEM EXTENSION
FOR VALVES 100mm (4") AND LARGER

WATER AGENCIES STANDARDS

COMMITTEE APPROVAL: 03/01/2001

DRAWING NUMBER: WV-04

K:\WAS\Water\Updated 9-03-01\wv04.dgn 20-SEP-2001 16:35